

Riverside Plant / Geismar, La.

DETONTATION ARRESTOR INSPECTION

Device: G-1151-DA1 Date of Inspection: Jun./2018
Inspected By: Thomas Pinell
Description: _____ Last Inspection: _____
Location: Dock #3
Type of Device & Function: Flame Arrestor

Testing Frequency: 1 years

Type of Test Performed:

Remove and inspect for physical damage and blockage

Results of Test:

Passed Inspection

Corrective Action Taken, If Applicable:

Comments:

Signature: 

Date: 4/30/2018