

Riverside Plant / Geismar, La.

ALARM & SHUTDOWN INSPECTION

Device: AIT-1139B Date of Inspection: Apr. 2020

Inspected By: Thomas Pinell

Description: Oxygen Analyzer

Location: Dock #3

Type of Device & Function: Oxygen Analyzer

Set Point: 0 - 25%

Testing Frequency: 1 years

Type of Test Performed:

Simulated low flow and high oxygen, at 21% and received shutdown.

Results of Test:

OK

Corrective Action Taken, If Applicable:

Comments:

Signature: 

Date: 4/30/2020