



Force Industries LLC
Relief Valve Identification

P&ID
 PSV# 1133

Customer: Enlink
 Field: Riverside
 Deck: Barge Area
 Vessel Descr: PGP

Date: 3/5/2020
 Inspector: Chris Tetreault/Tory Breaux

PSV Data

MFG: A/G Size: 2
 Type: 81S16A24A-H Set: 260
 S/N: 1101-1804-133646 COTP: _____
 Capacity: 3530 SCFM Code: UV/NB
 Is Original nameplate on valve? Yes No
 Is Original nameplate readable? Yes No
 Does PSV have a UV NB Code Stamp? Yes No
 Service Fluid: Gas
 Spring Range: _____

Inlet			Outlet		
Size	Press. Class	End Type	Size	Press. Class	End Type
2	150	RF	3	150	RF

Remarks: _____

Test Kit Installed: Yes No Outlet of PSV-Short Vent Stack to Atmosphere: Yes No
 Block Valve on Inlet: Yes No PSV set with Backpressure on Outlet: Yes No
 Block Valve on Outlet: Yes No Outlet of PSV-Piping connected to other piping: Yes No

