

**Bells Run Facility**

**ALARM & SHUTDOWN INSPECTION**

Device: Flame Arrestor DA-<sup>301</sup>~~103~~ Date of Inspection: 7/27/20  
Description: Flame Arrestor DA-<sup>301</sup>~~103~~ Inspected By: K. CRIDLE  
Location: Dock System Last Inspection: 8/19

Type of Device & Function: FLAME ARRESTOR  
Set Point: N/A  
Testing Frequency: 1 years  
Type of Test Performed:

VISUAL INSPECTION  
AND CLEANING

Results of Test:  
O.K.

Corrective Action Taken, If Applicable:  
—

Comments:  
—

Signature: [Handwritten Signature]

Date: 8/20/20