

Riverside Plant / Geismar, La.

ALARM & SHUTDOWN INSPECTION

Device: ESD_1301 **Date of Inspection:** Mar. 2021

Inspected By: Thomas Pinell

Description: ESD Button

Location: Flare

Type of Device & Function: ESD Stations

Set Point:

Testing Frequency: 1 years

Type of Test Performed:

Results of Test:

Corrective Action Taken, If Applicable:

Comments:

Signature: 

Date: Mar. 2021