

Riverside Plant / Geismar, La.

ALARM & SHUTDOWN INSPECTION

Device: ESD_Ramp Date of Inspection: Mar. 2021

Inspected By: Thomas Pinell

Description: ESD Buttons

Location: Ramp and Walkway

Type of Device & Function: ESD Stations

Set Point:

Testing Frequency: 1 years

Type of Test Performed:

Pressed button and received shutdown.

Results of Test:

OK

Corrective Action Taken, If Applicable:

Comments:

Signature: 

Date: Mar. 2021