

Riverside Plant / Geismar, La.

ALARM & SHUTDOWN INSPECTION

Device: LSH\_1140 Date of Inspection: Mar. 2021

Inspected By: Thomas Pinell

Description: Vessel Overfill high alarm

Location: Dock #3

Type of Device & Function: Barge connection to level switches

Set Point:

Testing Frequency: 1 years

Type of Test Performed:

Turned bypass switch to normal and received alarm.

Results of Test:

OK

Corrective Action Taken, If Applicable:

Comments:

Signature: 

Date: Mar. 2021