

Riverside Plant / Geismar, La.

ALARM & SHUTDOWN INSPECTION

Device: PIT-1131 Date of Inspection: Mar. 2021

Inspected By: Thomas Pinell

Description: High Pressure Dock Vapor Header

Location: Dock #3

Type of Device & Function: Pressure X-mitter

Set Point: -50 to 50"

Testing Frequency: 1 years

Type of Test Performed:

Pressured x-mitter up with hand pump. At 37" received high high pressure shutdown.

Results of Test:

OK

Corrective Action Taken, if Applicable:

Comments:

Signature: 

Date: Mar. 2021