

Riverside Plant / Geismar, La.

ALARM & SHUTDOWN INSPECTION

Device: TE--1116 Date of Inspection: Mar. 2021
Inspected By: Thomas Pinell
Description: DA-1101 Outlet Temp
Location: Dock #1

Type of Device & Function: Thermocouple
Set Point: 0 - 2500 deg F
Testing Frequency: 1 years

Type of Test Performed:
Simulated temp and received shutdown at 250 degrees

Results of Test:
OK

Corrective Action Taken, If Applicable:

Comments:

Signature:  Date: Mar. 2021