

Bells Run Facility

ALARM & SHUTDOWN INSPECTION

Device: ESL-101

Date of Inspection: _____

Description: Voltage Switch Low

Inspected By: _____

Location: Marine System

Last Inspection: _____

Type of Device & Function: _____

Set Point: _____

O₂ ANALYZER
HI O₂ ALARM / SHUTDOWN
16.5% O₂

Testing Frequency: 1 years

Type of Test Performed:

OPERATIONAL
ON STARTUP

Results of Test:

O.K.

Corrective Action Taken, If Applicable:

-

Comments:

-

Signature: _____

A. C. ...

Date: _____

8/4/21