

Bells Run Facility

ALARM & SHUTDOWN INSPECTION

Device: FSLL-101

Date of Inspection: 8/4/21  
Inspected By: W. CRIDER

Description: Flow Switch Low (Shutdown)

Last Inspection: 7/20

Location: Marine System

Type of Device & Function: O<sup>2</sup> ANALYZER LOW FLOW SW.

Set Point: 50 sccm

Testing Frequency: 1 years

Type of Test Performed:

OPERATIONAL

Results of Test:

O.K.

Corrective Action Taken, If Applicable:

—

Comments:

—

Signature: *W. Crider*

Date: 8/4/21