

Bells Run Facility

ALARM & SHUTDOWN INSPECTION

Device: PAHH-102

Date of Inspection: 8/4/21
Inspected By: A. CRIDER

Description: Pressure Alarm High

Last Inspection: 7/20

Location: Marine System

Type of Device & Function: HIGH HIGH VAPOR PRESS. ALARM

Set Point: 20" w.c.

Testing Frequency: 1 years

Type of Test Performed:

OPERATIONAL

Results of Test:

O.K.

Corrective Action Taken, If Applicable:

—

Comments:

—

Signature: A. Crider

Date: 8/4/21