

Bells Run Facility

ALARM & SHUTDOWN INSPECTION

Device: PSL-102

Date of Inspection: 8/4/21  
Inspected By: J. CRIBER

Description: Pressure Switch Low

Last Inspection: 7/20

Location: Marine System

Type of Device & Function: DOCK PANEL AIR PURGE

Set Point: 20" w.c.

Testing Frequency: 1 years

Type of Test Performed:

OPERATIONAL

Results of Test:

O.K.

Corrective Action Taken, If Applicable:

-

Comments:

-

Signature: J. Criber

Date: 8/4/21