

Bells Run Facility

ALARM & SHUTDOWN INSPECTION

Device: TAH-201

Date of Inspection: 8/4/21
Inspected By: T. CRIOER

Description: Temperature Analysis Hand/Manual

Last Inspection: 7/20

Location: Marine System

Type of Device & Function: HIGH TEMP. ALARM

Set Point: 200° F

Testing Frequency: 1 years

Type of Test Performed:

Force with meter

Results of Test:

O.K.

Corrective Action Taken, If Applicable:

-

Comments:

-

Signature: A. Cuid

Date: 8/4/21