

Bells Run Facility

ALARM & SHUTDOWN INSPECTION

Device: TSH-201

Date of Inspection: 8/4/21
Inspected By: L. CRIDER

Description: Temperature Switch High

Last Inspection: 7/20

Location: Marine System

Type of Device & Function: TEMP. SW. HIGH

Set Point: 200° F

Testing Frequency: 1 years

Type of Test Performed:

FORCE with meter

Results of Test:

O.K.

Corrective Action Taken, If Applicable:

-

Comments:

-

Signature: *A. Crider*

Date: 8/4/21