

Riverside Plant / Geismar, La.

ALARM & SHUTDOWN INSPECTION

Device: BSL_1272 **Date of Inspection:** Mar. 2022

Inspected By: Thomas Pinell

Description: Flame Scanner

Location: Flare 1301

Type of Device & Function: Flame Scanner for pilot

Set Point:

Testing Frequency: 1 years

Type of Test Performed:

Started flare pilot, then turned pilot fuel gas off, to receive loss of flame and shutdown.

Results of Test:

OK

Corrective Action Taken, if Applicable:

Comments:

Signature: 

Date: Mar. 2022