

Riverside Plant / Geismar, La.

Alarm & Shutdown Inspection

Device TAG: DIT1143 **Date of Test** Mar. 2022

Witnessed BY Thomas Pinell

Description: Density transmitter

Location: Dock #4 Barge Product line

Type of Device & Function: Pressure transmitter

Range 0-1 G/ml

Type of Test Performed:

Simulated Density and verified on HMI

Results of Test:

Worked Properly

Corrective Action Taken, If Applicable:

Comments:

Signature: 

Date: _____