

**Riverside Plant / Geismar, La.**

**ALARM & SHUTDOWN INSPECTION**

**Device:** HS\_1101B **Date of Inspection:** Mar. 2022

**Inspected By:** Thomas Pinell

**Description:** Power Switch

**Location:** Dock #1

**Type of Device & Function:** PLC Loss of Power Shutdown

**Set Point:**

**Testing Frequency:** 1 years

**Type of Test Performed:**


Turned power off to PLC and received shutdown.

**Results of Test:**

OK

**Corrective Action Taken, If Applicable:**

**Comments:**

**Signature:** 

**Date:** Mar. 2022