

Riverside Plant / Geismar, La.

ALARM & SHUTDOWN INSPECTION

Device: LSHH_1106 **Date of Inspection:** Mar. 2022

Inspected By: Thomas Pinell

Description: Vessel Overfill high alarm

Location: Dock #1

Type of Device & Function: Barge connection to level switches

Set Point:

Testing Frequency: 1 years

Type of Test Performed:

Turned bypass switch to normal and received Shutdown.

Results of Test:

OK

Corrective Action Taken, If Applicable:

Comments:

Signature: 

Date: Mar. 2022