

Riverside Plant / Geismar, La.

ALARM & SHUTDOWN INSPECTION

Device: PIT-702D

Date of Inspection: Mar. 2022

Inspected By: Thomas Pinell

Description: Fuel Gas Pressurizing Line

Location: Dock #4

Type of Device & Function: Pressure X-mitter

Set Point: HH- 250 Psi

Testing Frequency: 1 years

Type of Test Performed:

Simulated high pressure to receive alarm.

Results of Test:

OK

Corrective Action Taken, if Applicable:

Comments:

Signature: 

Date: Mar. 2022